

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 639

Dated: 24/08/2021

FIRE SAFETY CERTIFICATE

Certified that the building Delhi International School (Great Harsh Educational welfare & Charitable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi comprised of Ground + 03 Upper Floors owned/occupied by Great Harsh Educational welfare & Charitable Society was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1739 Dated 25/07/2018. The premises was re inspected by the officers concerned of this department on 04/08/2021 in the presence of Sh. Naresh Kumar (TO) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298 -3398 Dated 01/03/2011 and that the premises is fit for occupancy class-B "Educational" with effect from 24/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/8/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Sh. Naresh Kumar Delhi International School (Great Harsh Educational welfare & Charitable Society) Located at Sector – 18, Dwarka Phase – II, New Delhi.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 **The fixed windows are found provided in class rooms & staircases. The windows must be converted into open able windows within one month under intimation to this department.**
- 2 The new block comprising of ground plus one upper floor shall not be used without getting FSC from this department.
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 9 Basement shall be used strictly as per building bye laws.
- 10 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.